

Fire Pre Plan

				ID:	
ADDRESS:					
205 Pacific Avenue South					
Email:		Phone:		FAX:	
		642-3482			
Contacts:					
Rick - 503-791-0444 Cell Phone Manager					
Assigned Inspector:		Business License Number:		Occupancy Zone:	
				C1	
National Grid:		Assessor Parcel Number:		Assessed Value:	
Map Page:		Construction Type:		Occupancy Type:	
		V			
Roof Type:		Roof Type Material:		Roof Type Construction:	
Number of Units:		Occupancy Load:		Year Built:	
Property Use:				Time Normally Occupied:	
Store, Restaurant & Apartment				24 Hours	
Building Status:				Critical Infrastructure:	
Occupied					
Notes:					
Fire Alarm Panel Location:				Master Key Location:	
None				None	
Gas/LPG Shutoff Location:				Electrical Panel Location:	
3 Tanks West Side				Multiple, See map	
FD Connections:				Sprinkler Room Location:	
None				None	
Other Location Information:				Basement Present:	
				No	
Building Height:	Number of Floors:	Square Feet:	Length:	Width:	
30	2	17,500	135	100	
Water Supply Info:	Hydrant 1 - Bolstad & Pacific / 1150 GPM; Hydrant 2 - 3rd Steet South & Ocean Beach Blvd / 1130 GPM; Hydrant 3 - 3rd Street South & Oregon / 1140 GPM				
Exposure Info:					
Hazmat:					
Building Access:	See Below				
Access Problems:	Clothes Racks everywhere, 2nd floor is a maze.				
Ventilation Problems:	None				
Pre-Fire Plan Notes:					
Fire Protection Systems:	None				
Attachment Comments:					